



Sudo Room Outlet Details				
Label	Breaker	Voltage	Description	Plug Type
A	Balc #6_20A	120V	Upper Level_Server	Quad
B	Balc #6_20A	120V	Upper Level_Server	Quad
C	Balc #11_20A	120V	3D Printer	Quad
D	Balc #11_20A	120V	Museum	Quad
E	Balc #10_20A	120V	Overhead	L5-20r
F	Balc #10_20A	120V	Overhead	L5-20r
G	Balc #12_20A	120V	60" up_South Wall	Dual
H	Balc #12_20A	120V	60" up_South Wall	Dual
I	Balc #12_20A	120V	West Wall	Dual
J	Balc #12_20A	120V	West Wall	Dual
K	Balc #12_20A	120V	West Wall	Dual
L	A.Stg #15/16_30A	240V	Robot Arm	L6-20r/TBD
M	A.Stg#?/? 20A	240V	Unknown	TBD

Note: Outlets are on lower level 18" off the ground unless other wise noted

August 2014	REVISION 1.0
<b>Lawrence Engineering</b>	
TITLE: Sudo Room Electrical	
DWG NO. E1-Plan	A3
Drawing not to scale	SHEET 2 OF 8